



2013 CPC 909.0

Special Venting for Island Fixtures

Traps for island sinks and similar equipment shall be roughed in above the floor and may be vented by extending the vent as high as possible, but not less than drain board height. The vent is then returned downward and connected to the horizontal sink drain immediately downstream from the vertical fixture drain. Figure 6-16 illustrates the construction of the completed island venting system.

The returned vent shall be connected to the horizontal drain through a wye branch fitting, (see "b" in Fig. 6-15) and shall in addition be provided with a foot vent taken off the vertical fixture vent by means of a wye branch fitting immediately below the floor. This foot vent extends to the nearest partition and thence through the roof to the open air, or may be connected to other vents at a point not less than (6) inches (152.4 mm) above the flood level rim of the fixture served. (See Fig. 6-15.)

